

TAMILNADU FIRE AND RESCUE SERVICES

FIRE SAFETY CERTIFICATE

No : 59/2026

R.C NO: 1278/ V / VLY /2026

DATE : 19/ 08 / 2026

Certified that the **M/S. HOLY PRINCE VIDYALAYA** (Name of the building or premises) at **S.No 213/3A1 & 213/3A2, KANNI AMMAN KOIL STREET, PERIYAR NAGAR, MADIPAKKAM, CHENNAI- 600 091.** (address) comprised of Nil basement (s) **Ground, First, Second, Third Floor**(upper floors)owned/occupied **M/S. HOLY PRINCE VIDYALAYA** (name of the institution)have complied with the fire prevention and fire safety requirements in accordance With rule of state /UT Fire Service Rules and Verified by the officer concered of fire service on **19/08/2026** (date of inspection) in the presence of **Mr.S.Marimuthu, Principal** (name and address of the Manager / Secretary or his representative) and that the building/ premises is fit for occupancy **Pre KG to Class X (X/XII)** with effect from **19 / 08 /2026** for a period of **One year** in accordance with rule and subject to compliance of the conditions.

1. All the Fire Extinguishers have to be recharged placement and maintained periodically as per BIS 2190/2010.
2. Periodical Maintained should be ensured to keep all fire production equipments and system always in good condition.
3. National building code-2016 Fire & Life safety part-IV should be followed.
4. Fire Drill should be conduct as per NBC-2016.

Issued **19/ 08 / 2026** (date of issue) at **Velachery** (place) By

*Strike out whichever is not applicable



Signature With Seal :

Name

: D. PRABAKARAN

Designation

: Station Officer

STATION OFFICER
VELACHERY FIRE & RESCUE STATION
CHENNAI 600 042.

TO:

M/S. HOLY PRINCE VIDYALAYA ,
S.No 213/3A1 & 213/3A2,
KANNI AMMAN KOIL STREET, PERIYAR NAGAR,
MADIPAKKAM, CHENNAI- 600 091.

Copy To :

- 1.District Officer, Chennai City South District,
2. Station Officer , Velachery